



Attestation of Conformity

No. N8A 075834 0841 Rev. 00

Holder of Attestation: **Shenzhen MEGMEET Electrical Co., Ltd.**

5th Floor, Tower A, B,C501-C503,D,E
Unis Inforport, No.13 Langshan Road
North Section, Hi-Tech Industrial Park
Nanshan District
518057 Shenzhen
PEOPLE'S REPUBLIC OF CHINA

Product: **Programmable Controller**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 68240260691701

Date, 2026-08-12

(Alex Kong)

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 075834 0841 Rev. 00

Model(s): MU200-1210BTA, MU200-1210BRA, MU200-1616BTA, MU200-1616BRA, MU200-2424BTA, MU200-2424BRA, MU200-3232BTA, MU200-3232BRA, MU200-4040BTA, MU200-4040BRA, MU300-0808BTA, MU300-1210BTA, MU300-1210BRA, MU300-2424BTA, MU200-4DA, MU200-4AD, MU200-4PT, MU200-4AM, MU200-8TC, MU200-8AD, MU200-0808ERN, MU200-0808ETN, MU200-0016ERN, MU200-0016ETN, MU200-1600ENN

Brand: MEGMEET

MEGMEET

Parameters:

Ratings: See below table for details

Remarks:

- When installing the equipment, all requirements of the mentioned standard must be fulfilled.
- Open-type equipment, suitable enclosure should be provided in end system.
- The maximum operating temperature is 50°C.
- Clearance was evaluated for operating altitude up to 2000m above sea level.

Tested according to: EN 61010-1:2010/A1:2019
EN IEC 61010-2-201:2018

Page 2 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 075834 0841 Rev. 00

	Model	Input	Output
Main modules	MU200-1210BTA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU200-1210BRA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU200-1616BTA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU200-1616BRA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU200-2424BTA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU200-2424BRA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU200-3232BTA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU200-3232BRA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU200-4040BTA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU200-4040BRA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU300-0808BTA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU300-1210BTA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU300-1210BRA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
	MU300-2424BTA	100-240VAC, 50/60Hz, 1.0A	24VDC, 0.3A
Expansion modules	MU200-4DA	24VDC, 0.3A	--
	MU200-4AD	24VDC, 0.1A	--
	MU200-4PT	24VDC, 0.1A	--
	MU200-4AM	24VDC, 0.1A	--
	MU200-8TC	24VDC, 0.1A	--
	MU200-8AD	24VDC, 0.1A	--
	MU200-0808ERN	24VDC, 0.1A	--
	MU200-0808ETN	24VDC, 0.1A	--
	MU200-0016ERN	24VDC, 0.1A	--
	MU200-0016ETN	24VDC, 0.1A	--
	MU200-1600ENN	24VDC, 0.1A	--

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.